



NOTES:

1. ALL SERVICES TO BE WET TAP
2. #8 LOCATOR WIRE-STRANDED BLUE. USE A SINGLE LENGTH OF WIRE WITH INSULATION INTACT. COAT AT END OF WIRE WITH SCOTCHCOTE ELECTRICAL COATING OR EQUAL.
3. METER DIALS TO BE 152mm(6") FROM TOP OF BOX.
4. ALL METERS TO BE CENTERED IN BOX VERTICALLY AND HORIZONTALLY. METERS STOPS TO BE READILY ACCESSIBLE.
5. NO COMPRESSION FITTINGS TO BE USED WITHOUT APPROVAL OF WATER DEPARTMENT.
6. INSTA-TITE (MUELLER) FITTINGS TO BE USED ON ALL 19mm(3/4") AND 25mm(1") POLYETHYLENE SERVICE CONNECTIONS.
7. NO DAMAGED METER BOX SHALL BE INSTALLED I.E. BOX ENDS BROKEN OUT TO ACCOMMODATE METERS, SET INAPPROPRIATELY.

All units are in metric
Non-metric units in brackets

ACAD FILENAME: WATSERV

WATER METER SIZE	BOX SIZE * CHRISTY/LID
16mm(5/8")	B9 / B9D
25mm(1")	B16/B16E
38mm(1 1/2")	B30/B30E
51mm(2")	B30/B30E

* OR APPROVED EQUAL

CITY OF MENLO PARK STANDARD DETAILS



NO.	REVISIONS	DATE

**19, 25, 38 AND 51mm
(3/4", 1", 1 1/2" AND 2")
STANDARD WATER SERVICE**

APPROVED
for Y.A. Omer
Director of Engineering Services R.C.E. No.40998

DRAWN	CHECKED	DATE 1-1-97	SCALE NTS	SHEET 1 OF 1
-------	---------	-------------	-----------	--------------

STD. DETAIL No.: **WA-17**