



NOTES:

1. Place fire hydrant behind sidewalk where sidewalk and curb is a total of 1.83m(6') wide or less.
2. Fire hydrant and pad must be within street right-of-way or P.U.E.
3. Do not locate street light or tree at same property line junction as fire hydrant.

All units are in metric
Non-metric units are in brackets

ACAD FILENAME: FIREHYD

CITY OF MENLO PARK STANDARD DETAILS



NO.	REVISIONS	DATE

FIRE HYDRANT LOCATION

APPROVED

Leo A. Orman
for Director of Engineering Services R.C.E. No. 40898

DRAWN CHECKED NN DATE 1-1-97 SCALE NTS SHEET 1 OF 1

STD. DETAIL No.: **WA-2**